WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30021
Permit No.
Basin 8-101

WELL DRILLERS REPORT

Please complete this form in its entirety

INTENT #10097

1. OWNER Dick Whalen 806 SUNSET FALLON 89406 WELL ADDRESS 5174 Sandalwood Dr FALLON

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 19 N/S R. 28 E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	9	9
Clay		9	11	2
Fine Sand	x	11	36	25
Dark Clay		36	50	14
Brn Clay		50	53	3
Sand	x	53	66	13

'88 JUN -6 A11:54
STATE ENGINEER'S OFFICE

Date started May 24, 1988
Date completed May 24, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Blown @ 45 G.P.M.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 5/8 inches Total depth 66 feet
Casing record 6 5/8 x 66
Weight per foot 12.9 Thickness .188

Diameter	From	To
10 inches	0 feet	50 feet
6 inches	50 feet	66 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from — feet to — feet

Perforations:
Type perforation Machine slot
Size perforation 3/32 x 3'
From 55 feet to 63 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 8
Flow G.P.M.
Water temperature 59 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name V.W. Biffle
Address Box 888
Nevada contractor's license number 11752
Nevada driller's license number 772
Signed V.W. Biffle
Date May 31-88

USE ADDITIONAL SHEETS IF NECESSARY

O-627