WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30024
Permit No.
Basin 105 CARSON V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10898

1. OWNER Ray Bergman
MAILING ADDRESS 3137 Bodie Rd Gardnerville, Nev
ADDRESS AT WELL LOCATION 3137 Bodie Rd Gardnerville, Nevada
2. LOCATION NW ¼ NE ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. 35-254-02 Spring Valley Ranches
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden Sand & pebbles		0	5	5
Hard Compacted Clay		5	8	3
Cemented pea gravels with Clay Stringers Medium Hard to hard		8	70	62
Sand stone, grey with clay seams		70	91	21
Cemented pea gravel with fractures carrying	✓	91	120	29
T.D. 120 Feet				

Date started June 2, 1988
Date completed June 6, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with Air & Gravel packed. Blew to Clean for 2 hrs from 100			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 120 feet
..... inches
..... inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+3 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 51 feet below land surface
Flow 35 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address 5541 Hwy 50 E Carson City, Nev 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1477
Signed [signature]
By driller performing actual drilling on site or contractor
Date July 8, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627