

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9576

1. OWNER GREG & DANETTE SUHL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11825 Chesapeak 1383 Antelope Valley Road
Reno, NV 89506 Reno, NV 89506
 2. LOCATION NW 1/4 SW 1/4 Sec. 23 T. 22N R. 19 E. Washoe County
 PERMIT NO. 079-470-1180 Parcel No. Antelope valley Red Rock Est. H-270
 Issued by Water Resources Subdivision Name part-1

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown sandy clay		0	6	6
Fine light brown sand		6	49	43
Soft brown sandy clay		49	86	37
Brown clay		86	109	23
Weathered granite		109	111	2
Green granite		111	125	14
Fracture, soft zone	X	125	140	15
Weathered granite with clay streaks		140	161	21
Green hard granite		161	168	7

'88 JUL 17 1956
 STATE ENGINEER

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 168 feet

Casing record 168' steel casing installed.

Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>168</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 168 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around

From	To
<u>123</u> feet	<u>163</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 5-24-88, 19____
 Date completed 5-27-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 63 feet below land surface

Flow 30 G.P.M. _____ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor

Nevada contractor's license number 22549
 issued by the State Contractor's Board

Nevada contractor's driller's number 908
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Wayne Drilling, Inc.
 by driller performing actual drilling on site or contractor

Date June 1, 1988