



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10312

1. OWNER RON & ROBIN RIOS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 440 Palace Drive 525 Oregon Blvd.
Reno, Nv 89506 Reno, NV 89506
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 21N N/S R. 19 E Washoe County
 PERMIT NO. _____ Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine brown blow sand		0	8	8
Brown sandy clay		8	116	108
Weathered granite		116	186	70
Soft zone (NO WATER)		186	188	2
Gray hard granite		188	232	44
soft zone (NO WATER)		232	234	2
Gray hard granite		234	242	8
Soft zone (NO WATER)		242	243	1
Gray hard granite		243	259	16
Weatthered granite		259	264	5
Gray hard granite		264	303	39
Soft zone (app. 3 GPM)	X	303	307	4
Gray hard granite		307	343	36
Fracture (NO WATER)		343	344	1
Gray hard granite		344	355	11
Fracture	X	355	356	1
Gray granite		356	360	4
Fracture	X	360	361	1
Gray granite		361	370	9
Fracture	X	370	372	2
Gray granite		372	390	18

* 39.691
 119.844

* See Logging Log # 110078

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 390 feet
 _____ inches
 _____ inches
 Casing record 390' steel casing installed
 Weight per foot _____ Thickness .156
 Diameter From To
6 5/8 inches 0 feet 390 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal _____ 52 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 390 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
341 feet to 381 feet
 From _____ feet to _____ feet

Date started 5-31-88, 19____
 Date completed 6-2-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

188 STATE ENGINEER

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 263 feet below land surface
 Flow 34 G.P.M. P.S.I. _____
 Water temperature cold°F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signature [Signature]
 By driller performing actual drilling on site or contractor
 Date June 3, 1988