

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10313

1. OWNER BONUS INVESTMENT GROUP ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 571 California Ave. 17996 Dalton Lane  
Reno, NV 89509 Reno, NV 89506  
 2. LOCATION NE 1/4 NE 1/4 Sec. 20 T. 21N N/S R. 18 E Washoe County  
 PERMIT NO. 87-021-15 Cold Springs  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air/Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Coarse sand w/brown clay		1	28	27
Decomposed granite w/brown clays		28	40	12
Green granite w/white clay, weathered		40	45	5
Gray granite, hard		45	49 1/2	4 1/2
Gray granite w/brown clays, soft		49 1/2	63 1/2	14
Gray granite, hard		63 1/2	67 1/2	4
Gray granite w/brown clayey		67 1/2	83	5 1/2
Green granite, weathred fracture	X	83	122	39
Gray granite		122	143	21
Soft fractured granite	X	143	161	18
Gray granite		161	165	4
Fracturee broken rusty granite	X	165	180	15

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 180 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 180' steel casing installed.  
 Weight per foot \_\_\_\_\_ Thickness 1.56  
 Diameter From To  
6 5/8 inches 0 feet 180 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement \_\_\_\_\_  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 180 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 136 feet to 176 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-3-88, 19\_\_\_\_\_  
 Date completed 6-4-88, 19\_\_\_\_\_  
 \_\_\_\_\_

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Flow 18.75 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board.  
 Nevada contractor's driller's number 908  
 issued by the Division of Water Resources.  
 Nevada driller's license number 1535 issued by the Division of Water Resources the on-site driller.  
 Signed Wayne Drilling, Inc.  
 By driller performing actual drilling on site or contractor  
 Date June 6, 1988

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours