WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30056
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6341

1. OWNER Andy Galio
MAILING ADDRESS Box 2114 Fallon, Nevada
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NE ¼ Sec. 34 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 10-541-10 | Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	1	1
CLAY		1	10	9
SILT		10	11	1
CLAY		11	29	18
SAND + CLAY		29	34	5
TULE CLAY		34	39	5
SILT + CLAY		39	40	1
BLACK CLAY		40	60	20
GRAY SAND		60	70	10
GRAY CLAY		70	72	2
BROWN CLAY		72	80	6
SILT + SAND		80	86	6
GRAY CLAY		86	100	14
SILT + FINE SAND		100	105	5
GRAY CLAY		105	112	7
SILT + FINE SAND		112	120	8
CLAY		120	125	5
FINE SAND + CLAY		125	137	12

Galio Told me to stop and He would try to get waiver No waiver was given so I didn't go back. My opinion was the well should be deeper for suitable water strata (over on back)

Date started Nov 15, 1987
Date completed ..., 19..

STATE ENGINEERS OFFICE RECEIVED NOV 30 '87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	11:69	88	

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 137 feet
..... inches
..... inches

Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
10 inches	0 feet	50 feet
6 inches	0 feet	137 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch Cut
Size perforation 1/8 x 4
From 127 feet to 136 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level ..... feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON CANNON JR
Contractor
Address 1870 ROBERSON LN
2900 TARZYN Rd FALLON
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources 1455
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr.
By driller performing actual drilling on site or contractor
Date

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

This well had a waiver denied for 86-92' by Dick Williford. The well located less ~~that~~ than 1/4 mile from Carson River to the north. Less than 1/4 mile to the south is a main irrigation canal.

The 137 ft well would pull down with bailer to 50'-60' with 1-2 bailer fulls.

The well would probably have to be drilled to 177 to 210 ft. for suitable water bearing material.