WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 30061
Permit No.
Basin G-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1690

1. OWNER Dery Bailey Construction
MAILING ADDRESS 3116 Thomas Jefferson
Reno, Nevada
ADDRESS AT WELL LOCATION 190 Spear St.
North Washoe City, NV

2. LOCATION SE ¼ NE ¼ Sec. 36 T. 17 N/S R. 24 E/W Washoe County
PERMIT NO. 11CH, cc 3770 (Issued by Water Resources) | 5C-273-1-4 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden at Reno airport and Caliente | | 0 | 7 | 7 |
| Granodiorite, Soft to Medium Hard | | 7 | 147 | 140 |
| Fractured granite w/ water, 3-4 GPM | ✓ | 147 | 153 | 6 |
| Granite, gray to white, very hard & fine grained | | 153 | 240 | |
| Granite, blue-grey, very hard fractured from 267-272 ft carrying small amount water | ✓ | 240 | | |
| T.D. = 275' | | | | |

Date started June 16, 19 55
Date completed June 22, 19 55

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches, 8 1/2 inches, ..... inches Total depth 275 feet
Casing record 6 5/8 O.D. Steel
Weight per foot 11.7 Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | + 2 feet | 275 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 275 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3
From 245 feet to 265 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 85 feet below land surface
Flow 8-10 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H. E. H. Dumpe Co. (Contractor)
Address 5540 Mill St. Reno, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 25795
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1112
Signed William Potts (By driller performing actual drilling on site or contractor)
Date July 23, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627