WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30068
Permit No.
Basin 8-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10902

1. OWNER Richard Leigh
MAILING ADDRESS 3448 Bernese Ct
Minden, Nevada

ADDRESS AT WELL LOCATION
3448 Bernese Ct
Minden, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 11 T. 14 N S.R. 19 E. Douglas County
PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name: Alpine View Estates

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandstone, brown to yellow		114	172	58
Granodiorite, grey to white, medium to hard fine grained with fractures from 172 to 187 with limited water	✓	172	187	15
Granodiorite solid, white, fine grained very hard		187	200	13
T.D. 200 ft				
Note 4-5 GPM from upper aquafer				

Date started June 22, 1988
Date completed June 23, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow well to develop + clean set 6" liner from 97-200 Extending up into existing 8" Casing. 12-15 GPM from 190'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 200 feet
..... inches
..... inches
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	97 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal unknown feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 97 feet to 117 feet
From 180 feet to 200 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow 12-15 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address 5351 Hwy 50 E #3 Carson City, Nv 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton Butts
By driller performing actual drilling on site or contractor
Date 6/24/88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627