

OFFICE USE ONLY
 Log No. 30074
 Permit No. _____
 Basin G-89

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9508

PRINT OR TYPE ONLY

1. OWNER Duane Dermody ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1225 Brenda Way 2485 Eastlake Blvd.
Carson City, Nv 89704 Lot 9 Block I # 3
 2. LOCATION SW 1/4 NE 1/4 Sec. 31 T 17 N/S R. 20 E Washoe County _____
 PERMIT NO. 50-385-09 - New Washoe City
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. sands fine		0	48	48
Decomposed granite firm some fractures		48	102	54
Hard granite black & white some brown & tan [Hard]		102	120	18
T.D. 120				

*88 JUN 20 10:42 AM '88 STATE ENGINEER

8. 10" - 60" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 120 feet
7 1/8 inches
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from 54 feet to 120 feet

Perforations:
 Type perforation factory
 Size perforation 1/8 X 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6/3/88, 19____
 Date completed 6/6/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean & develop.			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 70 feet below land surface
 Flow 11 G.P.M. P.S.I. _____
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
Contractor
 Address 625 Spice Islands Dr. Suite L Sparks, Nv
Contractor 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date _____