

OFFICE USE ONLY  
 Log No. 30076  
 Permit No. \_\_\_\_\_  
 Basin 7-92b

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10141

1. OWNER Spence Bitz Realty & Construction ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 575 Mill St. 440 Alaska  
Reno, Nv. 89502 Reno, Nv. 89506  
 2. LOCATION SE 1/4 NE 1/4 Sec. 23 T. 21 N/S R. 19 E Washoe County  
 PERMIT NO. \_\_\_\_\_ 080-216-004 Lemmon Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown clay		1/2	61	60 1/2
soft zone		61	63	2
Soft brown sandy clay		63	83	20
Soft zone		83	86	3
Brown sandy clay		86	91	5
Soft zone	X	91	94	3
Brown sandy clay		94	111	17
Soft zone	X	111	128	17
Brown clay		128	134	6
Soft zone	X	134	143	9
Soft sandy brown clay		143	146	3

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 146 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 146' steel casing installed  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>146</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 146 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-21-88, 19\_\_\_\_\_  
 Date completed 6-21-88, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 57 feet below land surface  
 Flow 20 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC.  
Contractor  
 Address P.O. Box 12370 Reno, Nv. 89510  
Contractor  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
By driller performing actual drilling on site or contractor  
 Date June 23, 1988

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours