

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY 14 DAF

NOTICE OF INTENT NO: 8129

1. OWNER Gerald Voivod ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11655 Mistletoe 1455 Antelope Valley Rd. #2445
Lemon Valley Nevada 89506 Reno, Nevada
 2. LOCATION ne 1/4 se 1/4 Sec. 14 T. 22 S/R. 19 E. Washoe County
 PERMIT NO. N/A 79-480-48-21 Red Bone Rock Estates #256 Par. 2
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Sand		0	2	
Brown clay XXXXXX		2	75	
Brown clay w/sand		75	93	
Hard fractured granite		93	160	
Mult. col. brkn. granite	x	160	175	
Hard granite		175	185	
mult. col. brkn granite	x	185	195	
Hard fractured granite		195	200+	

8. WELL CONSTRUCTION

Diameter 65/8 inches Total depth 200' feet
 _____ inches
 _____ inches
 Casing record 65/8 o.d. steel
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>12 1/2</u> inches	<u>0</u> feet	<u>10</u> feet
<u>10</u> inches	<u>10</u> feet	<u>117</u> feet
<u>8 1/2</u> inches	<u>117</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 53' feet
 Gravel packed: Yes No
 Gravel packed from 53' feet to 200' feet
 Perforations:
 Type perforation mill slot
 Size perforation 1/8 x 3
 From 160' feet to 200' feet
 From _____ feet to _____ feet

Date started 6/3, 1988.
 Date completed 6/30, 1988.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlifted to clean & develop for 45 min. approx. 30 gpm			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 90' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Pump & Drilling Contractor
 Address 7575 Iron Mt. Ranches Contractor
 Nevada contractor's license number issued by the State Contractor's Board 012236B
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1037
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6-16-88