


OFFICE USE ONLY  
 Log No. 30091  
 Permit No. \_\_\_\_\_  
 Basin. 8-103



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9510

PRINT OR TYPE ONLY

1. OWNER Alhambra Mines, Inc. ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 255 Glendale Ave Unit # 13 Six mile canyon - 2 1/2 miles East of  
Sparks, Nv 89431 Virginia City, Nevada

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T. 17 N/S R. 22E Storey County  
 PERMIT NO. 2510 EV-01 MH 12  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input checked="" type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light green & yellow clay		0	60	60
Blue gray clay		60	110	50
Green gray & white andisite		110	262	152
T.D. 262'				

8.8 1/2" - 60' WELL CONSTRUCTION

Diameter 6 1/2 inches Total depth 262 feet

Casing record 5 inch

Weight per foot 6.96 Thickness .134

Diameter	From	To
<u>5</u> inches	<u>+1 1/2</u> feet	<u>262</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type neat cement

Depth of seal 55 feet

Gravel packed: Yes  No

Gravel packed from 55 feet to 262 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From 182 feet to 262 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

1988 JUN 20 AM 10:42  
 RECEIVED  
 STATE ENGINEERS OF NV

Date started 6/9/88, 19\_\_\_\_  
 Date completed 6/10/88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 75 feet below land surface

Flow 1 - 2 G.P.M. P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources

Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller 1511

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor

Date 6/14/88