WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30096
Permit No.
Basin 8-101

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER NAVY ADDRESS Fuel Farm, Naval Air Station, Fallon, Nevada

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 18 (N)S R. 29 E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒ Monitoring

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ 8" hollow

6. Well #17 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND - fine to coarse grain, mottled color		0	15'	15'
Water Level	8'	8'	15'	
Well Developed for testing pumped 75 gal.				

Date started April 26, 19 88
Date completed April 26, 19 88

7. WELL TEST DATA N/A

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST N/A
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION stem auger
Diameter hole 8" inches Total depth 15 feet
Casing record Schedule 40 PVC
Weight per foot -------- Thickness ----

Diameter	From	To
2 inches	0 feet	5 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement & Sand
Depth of seal 2 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 3 feet to 15 feet
Sanitary Seal (1/2" bentonite) 3 to 2 feet
Perforations:
Type perforation machine slotted
Size perforation .02 inch
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 3928.5msl Feet below land surface 8'
Flow G.P.M.
Water temperature 18°C. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature]
Address 2708 Pinewood Dr. Sparks Nev.
Nevada contractor's license number
Nevada driller's license number 1028
Signed [signature]
Date 5/6/88

USE ADDITIONAL SHEETS IF NECESSARY

5471