WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30108
Permit No. 49419-420-421
Basin CARSON V.-105-
5207604

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10048

1. OWNER ROBERT AND VAL EASTERWOOD
WHITE RABBIT ASSOCIATES
MAILING ADDRESS c/o VASEY ENGINEERING CO.
P. O. BOX 247 MINDEN, NEVADA 89423

ADDRESS AT WELL LOCATION
KRISTY LANE - EAST MINDEN

2. LOCATION ~~SW~~ SE ~~SW~~ SE 1/4 Sec. ~~20~~ 26 13 N/S R. 20 E. DOUGLAS County
M.D.B.&M.

PERMIT NO. 49419/49420/49421 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PW# 1 PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand, gravel, clay		0	80	80
large gravel, sand, broken rock chips		80	120	40
large gravel & sand with clay layers		120	170	50
medium to large gravel	XX	170	180	10
med to small gravel little clay	XX	180	220	40
med to small gravel with clay layers		220	240	20
clay, sand, small gravel	XX	240	300	60
med. to small gravel, sand, some clay	XX	300	356	56
clay		356	360	4
clay, chirt, silt, med. to small gravel	XX	360	380	20
clay, silt to fine sand	XX	380	503	123
Electric geophysical well log by: Geo-Hydro Data				

Date started APRIL 26, 1988
Date completed JULY 1, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	350	1/2	½
	450	19½	1
	550	32½	1
	500	37½	31

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14-3/4 inches Total depth 408 feet
..... inches
..... inches
Casing record 10-3/4" O.D. x 1/4" mild steel
Weight per foot 28.04 Thickness .....

Diameter	From	To
22 - 18 inches	+1 feet	79 feet
..... inches	..... feet	..... feet
10 inches	+1 feet	408 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☒ No ☐ Type cement sand grout
Depth of seal 79 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from +1 feet to 408 feet
Chevreaux 1/8" x 1/4" quartz pebbles
Perforations:
Type perforation Milled
Size perforation 3" x 1/8" double standard spacing
From 108 feet to 408 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 152½ feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NORTH VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JULY 8, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627