WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30116
Permit No. 48998
Basin 4-72

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10058

1. OWNER FLORIDA CANYON MINING INC.
MAILING ADDRESS P. O. BOX 330
IMLAY, NEVADA 89418

ADDRESS AT WELL LOCATION
REPLACEMENT WELL #1

2. LOCATION SE ¼ NW ¼ Sec. 3 T 31 (N) S R 33 E HUMBOLDT County

PERMIT NO. 48998 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| broken rock, clay, & boulders | | 0 | 80 | 80 |
| broken rock & clay | | 80 | 200 | 120 |
| clay w/some sand & broken rock | | 200 | 220 | 20 |
| gray & tan clay w/some clay | | 220 | 240 | 20 |
| red clay & coarse sand mixed | | 240 | 552 | 312 |
| gray bedrock | XXX | 552 | 599 | 47 |

Date started JUNE 13, 1988
Date completed JUNE 22, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| air lift | 300 | | 3 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 14-3/4 inches Total depth 595 feet
..... inches
..... inches
Casing record 10-3/4" O.D. Type 304 Stainless Steel
Weight per foot 28.7 Thickness 1/4"

| Diameter | From | To |
|---|---|---|
| 10 inches | +1 feet | 595 feet |
| cement plug inches | 595 feet | 597 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 595 feet
Chevreaux 1/8" x 1/4" quartz pebbles
Perforations:
Type perforation Roscoe Moss 10-3/4" O.D. 304 S.S.
Size perforation .080" x 2-3/8" ful-flo louvered
From 495 feet to 595 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 121 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature hot °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NORTH VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1578
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JUNE 27, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627