

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

*14ABD*

NOTICE OF INTENT NO. 10306

1. OWNER P. JACKSON  
 MAILING ADDRESS 2665 Antelope Valley Rd.  
Reno, Nv. 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW 1/4 NE 1/4 Sec. 14 T. 22 N/S R. 19 E. Washoe County  
 PERMIT NO. 79-480-39 Issued by Water Resources Parcel No. \_\_\_\_\_  
Antelope Valley Rock Est. #2417 Subdivision Name Antelope Valley Rock Est. #2417

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Over burden		0	1	1
Decomposed granite brown medium		1	49	48
Decomposed granite brown soft		49	75	26
Granite, gray harder		75	130	55
Weathered granite, grayish brown, soft	X	130	168	38
Gray hard granite		168	182	14
Granite broken & fractured	X	182	189	7
Hard granite		198	201	3
softer granite		201	204	3

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 204 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 204' steel casing installed  
 Weight per foot \_\_\_\_\_ Thickness .156  
 Diameter From To  
6 5/8" inches 0 feet 204 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 204 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 161 feet to 201 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-24-88, 19\_\_\_\_  
 Date completed 6-25-88, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Flow 20 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370 Reno, Nv. 89510 Contractor  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date June 25, 1988