

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10299

PRINT OR TYPE ONLY

1. OWNER BILL ALBEE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3454 Lakeside Dr. 10275 Red Rock Rd.
Reno, Nv. 89509 Reno, Nv. 89506
 2. LOCATION SE 1/4 NE 1/4 Sec 26 T 21 N/S R 18 E Washoe County
 PERMIT NO. 087-330-16 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|---------|---------|------------|
| WELL DEEPENING | | | | |
| Sandy blue green clay | | 101 | 102 | 1 |
| Medium coarse sand w/ a lot of clay | | 102 | 128 | 26 |
| Sandy blue green clay | | 128 | 129 | 1 |
| Medium coarse sand w/ clay | | 129 | 138 | 9 |
| Sandy blue green clay | | 138 | 139 1/2 | 1 1/2 |
| Medium coarse sand less clays | X | 139 1/2 | 182 | 42 1/2 |

*Deepening of log #
26304*

8. WELL CONSTRUCTION
 Diameter 5 inches Total depth 182 feet
 _____ inches
 _____ inches
 Casing record 182' steel casing installed
 Weight per foot _____ Thickness 132

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>5</u> inches | <u>0</u> feet | <u>182</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from N/A feet to _____ feet
 Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 135 feet to 175 feet
 From _____ feet to _____ feet

Date started 6-22-88, 19____
 Date completed 6-23-88, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 40 feet below land surface
 Flow 8 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370 Reno, Nv. 89510
 Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date June 23, 1988