

OFFICE USE ONLY  
 Log No. 30127  
 Permit No. \_\_\_\_\_  
 Basin. 105 CARSON NV  
 NOTICE OF INTENT NO. 10850

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Helen Norvell ADDRESS AT WELL LOCATION 1017 Country Lane  
Carson City, NV 89701 Gardnerville, NV  
 2. LOCATION NW 1/4 NW 1/4 Sec. 20 T. 12 N S. 20 E Range 103 County  
 PERMIT NO. 27-710-04 Parcel No. \_\_\_\_\_ Subdivision Name Country Lane  
 Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>pea gravel, sand with large boulders to 18" diameter</u>		<u>6</u>	<u>38</u>	<u>32</u>
<u>Small to medium rock, 2"-6" with gravels and sand</u>	<input checked="" type="checkbox"/>	<u>38</u>	<u>120</u>	<u>82</u>
<u>T.D. 120 FT</u>				

700 JUL 19 1988 RECEIVED STATE ENGINEERS (111)

8. WELL CONSTRUCTION  
 Diameter 12" inches Total depth 120 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8" steel  
 Weight per foot \_\_\_\_\_ Thickness 1.88  
 Diameter From To  
6 inches 7 feet 120 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 60 feet  
 Gravel packed: Yes  No   
 Gravel packed from 60 feet to 120 feet  
 Perforations:  
 Type perforation Factory Mill Slot  
 Size perforation 3/32 x 3  
 From 93 feet to 113 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started July 13, 1988  
 Date completed July 15, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed with clean water to remove mud &amp; gravel pack</u>			
<u>Blew 30-40 GPM from 110' for 2 hours</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Flow 30+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name APA Pump Co  
5351 Hewlett Contractor  
Carson City, NV  
 Nevada contractor's license number 23295  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number \_\_\_\_\_  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11477  
 Signed Timothy Burt  
 by driller performing actual drilling on site or contractor  
 Date July 16, 1988