

OFFICE USE ONLY
 Log No. 30134
 Permit No. MONITOR ONLY
 Basin 59 - Lower Reese

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER STEREA PACIFIC POWER CO. ADDRESS P.O. Box 10100, RENO, NV 89520

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T. 32 N S R. 45 E LANDER County
 PERMIT NO. WATER - EY - 006

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE MONITOR
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty clay</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Fine to Med. Sand</u>		<u>5</u>	<u>6 1/2</u>	<u>1 1/2</u>
<u>Med. to Coarse Sand</u>		<u>6 1/2</u>	<u>10</u>	<u>3 1/2</u>
<u>"</u>		<u>10</u>	<u>11 1/2</u>	<u>1 1/2</u>
<u>Sandy Gravel</u>		<u>11 1/2</u>	<u>15</u>	<u>3 1/2</u>

*88 AGD -1 A10 44
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 15 feet
 Casing record PVC - Sch. 40
 Weight per foot _____ Thickness _____
 Diameter _____ From _____ To _____
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type GROUT
 Depth of seal 3 ft feet
 Gravel packed: Yes No
 Gravel packed from 5 feet to 15 feet
 Perforations:
 Type perforation MANUFACTURED SLOT
 Size perforation .02 in
 From 5 feet to 15 feet
 From _____ feet to _____ feet

Date started 7/7, 1988
 Date completed 7/7, 1988

7. WELL TEST DATA -NO TEST

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 6.11 Feet below land surface ✓
 Flow _____ G.P.M. _____
 Water temperature 68 ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name John Anderson
 Address 1635 Belford RD Reno NV
 Nevada contractor's license number _____
 Nevada driller's license number 1028
 Signed John Anderson
 Date 7/26/88