WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30146
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10851

1. OWNER Rick Kordowny
MAILING ADDRESS Box 813
Dayton, Nevada

ADDRESS AT WELL LOCATION
Dayton, Nevada

2. LOCATION NE ¼ SW ¼ Sec. 24 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name NONE

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cleaned out rock & rubble in Existing 8" Casing to 97'				
Red to black hard to very hard, fine grained volcanic rock with fractures carrying small quantities water	✓	97	140	43
T.D. 140 ft				
Set 6 5/8" Liner from 88' to to 140'				

Date started June 27, 1988
Date completed June 28, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop			
12-15 GPM from 130'			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 7 7/8 inches Total depth 140 feet
____ inches
____ inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	88 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type ____
Depth of seal unknown feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 120 feet to 140 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 47 feet below land surface
Flow 12-15 G.P.M. ____ P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co
Contractor
Address 5551 Hiway 50 E #3 Carson City, NV 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton Butt
By driller performing actual drilling on site or contractor
Date June 28, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627