WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30170
Permit No.
Basin 102 Churchill V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10678

1. OWNER Lambert Starrenburg
MAILING ADDRESS 8190 E Hooten St. Silver Springs Nev 8
ADDRESS AT WELL LOCATION 8190 E Hooten St Silver Springs Nev.

2. LOCATION NE ¼ NE ¼ Sec. 21 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 17-503-17 (Parcel No.) Carson River Acres (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0'	1'	1'
Clay + Sand		1	30'	29'
Clay + Gravel		30'	65'	35
Water (First)	65'			
Coarse Sand		65'	67'	2'
Clay		67	95	18'
Sand (Fine)	Little	95	110'	15'
Clay (tule)		110'	115'	5'
Gray Gravel (tule)	✓	115'	140'	35
Gray Clay		140'	142'	2'
Brown Clay		142'	175'	33'
Brown Sand + Gravel	✓	175	190'	15'
Water (Good				
Clay		190		

Water from 175 to 190 came up production casing to 27 ft from ground level
No Stink

Date started July 15, 1988
Date completed July 30, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	60	30 ft	9 hrs

Pumping Level 57 ft
Pump set at 85 ft

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 190 feet
inches
inches
Casing record
Weight per foot 17 Thickness 250

Diameter	From	To
10 inches	0 feet	50 feet
6 inches	0 feet	190 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Machined
Size perforation 1/16 x 2
From 181 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 27 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Jr (Contractor)
Address 1900 Tarzyn Rd Fallon (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources 1455
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr. (By driller performing actual drilling on site or contractor)
Date July 31, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627