WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30171
Permit No.
Basin 89 WASHOE VALLEY

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9933

1. OWNER [illegible]
MAILING ADDRESS 1535 [illegible]
[illegible]

ADDRESS AT WELL LOCATION
3730 Eagle
Carson City, NV

2. LOCATION [illegible] ¼ [illegible] ¼ Sec. 31 T. 17 N/S R. 20 E/W Washoe County
PERMIT NO. [illegible] (Issued by Water Resources) | 20-001-75 (Parcel No.) | New Washoe City #2 (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Blind

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine gray clay sand		0	7	7
Loose fine to medium fine sand		7	53	14
Cemented gravel sand to gravel - stony layers				
Brown sandstone Gravel layers clients		53	121	38
Blue gray to green clay - silty - gravel - coarse sand - [illegible] 121-153 Coarse sand		121	160	39
T.D. 160 ft				

Date started July 7, 19 55
Date completed July 12, 19 55

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with [illegible] to remove [illegible] [illegible]			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 3/4 inches Total depth 160 feet
..... inches
..... inches
Casing record 5 5/8 C.D.
Weight per foot ..... Thickness .155

Diameter	From	To
5 5/8 inches	12 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 160 feet

Perforations:
Type perforation Factory Slot
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 13 feet below land surface
Flow 10-15 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Pump Co.
Address 533 [illegible] Contractor Carson City, Nev. 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board [illegible]
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller [illegible]
Signed [illegible] By driller performing actual drilling on site or contractor
Date 7/13/55

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627