WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30212
Permit No.
Basin 105 - CARSON V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9146

1. OWNER HYDRO-SEARCH, INC.
MAILING ADDRESS 333 Flint Street, Reno, Nevada 89501

ADDRESS AT WELL LOCATION South Tahoe Refuse /Douglas County Landfill, Minden, Nevada
A-2

2. LOCATION NW ¼ SW ¼ Sec. 18 T. 12 N/S R. 21 E. DOUGLAS County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE MONITOR
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sandstone		0	60	
Silty claystone		60	100	
Silty conglomerate w/claystone		100	210	
Clayey conglomerate		210	320	
Sand & gravel		320	380	

AUG 11 A10 2
'88
STATE ENGINEER'S OFFICE

Date started July 14, 1988
Date completed July 26, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Airlift	4	93	6

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches, 7-7/8 inches, ... inches Total depth 380 feet
Casing record 2 inch Schedule 40 Steel
Weight per foot ..... Thickness .....

Diameter	From	To
Conductor inches	feet	feet
12 - 8 inches	+3 feet	95 feet
inches	feet	feet
8 - 2 inches	+2 feet	360 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Portland Cement
Depth of seal 95 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 95 feet to 380 feet
Monterey Sand #3

Perforations:
Type perforation 2" Stainless Steel Type 304
Size perforation .020" Slot Screen
From ..... feet to ..... feet
From 320 feet to 360 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 207 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. VIRGINIA ST., RENO, NEVADA 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22587
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1388
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 10, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627