WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30237
Permit No. 48603
Basin PAHRUMP V. -162-
NOTICE OF INTENT NO. 44164

PRINT OR TYPE ONLY

1. OWNER RON FLOYD
MAILING ADDRESS BOX 157
PAHRUMP, NEV. 89041

ADDRESS AT WELL LOCATION
N.W. CORNER OF WILSON
+ BLAGG PAHRUMP, NEV.

2. LOCATION S.E. ¼ N.E. ¼ Sec. 16 T. 20 N/S R. 53 E. NYE County
PERMIT NO. ~~48602~~ 48603 (Issued by Water Resources) Parcel No.
DIAMOND BAR ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
QUASI Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
SANDY BROWN CLAY		1	3	2
WHITE CALICHE		3	6	3
HARD BROWN CALICHE		6	43	37
GREY CALICHE		43	47	4
HARD BR. CALICHE		47	62	15
BROWN CALICHE		62	81	19
W/SOME GRAVEL				
HARD BROWN CALICHE		81	85	4
BROWN CALICHE		85	87	2
HARD BR. CALICHE		87	114	27
GREY CLAY		114	129	15
SANDY BROWN CLAY		129	140	11
+ CALICHE				
HARD BR. CALICHE		140	148	8
BROWN BENTONITE CLAY		148	169	21
SANDY BROWN CLAY		169	175	6
HARD BROWN CALICHE		175	182	7
BROWN CALICHE		182	190	8
HARD BROWN CALICHE		190	220	30

RECEIVED
JUL 19 1988
Div. of Water Resources
Branch Office · Las Vegas, NV

Date started 6-20, 1988
Date completed 6-27, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AUG 30 '88
STATE ENGINEER

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 220 feet
..... inches
..... inches
Casing record 220 FT 8 5/8" O.D. STEEL
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	220 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 100 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 37 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP + DRILLING (Contractor)
Address BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7479-A
Nevada contractor's driller's number issued by the Division of Water Resources 1424
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1427 STAN HARDIN
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-30-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627