WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30240
Permit No. 46505
Basin 153 - DIAMOND V.

NOTICE OF INTENT NO. 8259

1. OWNER Perry Burnham
MAILING ADDRESS PO Box 33 Eureka, NV 89316
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 8 T. 21 N/S R. 54 E Eureka County
PERMIT NO. 46505 (Issued by Water Resources) Parcel No. Diamond Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Reverse

6. LITHOLOGIC LOG
S+G = Sand + Gravel

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
Clay		3	4	
S+G		9	18	
Clay		18	19	
S+G		19	25	
Clay		25	30	
S+G		30	41	
green clay		41	63	
black clay		63	66	
Green Clay		66	115	
Black S+G		115	118	
Clay		118	124	
S+G		124	139	15
Clay		139	150	
S+G		150	156	6
Clay		156	177	
S+G up to 1/4"		177	181	4
Clay		181	182	
S+G		182	218	36
S+G - some clay		218	227	9
Clay		227	232	
Hard White sandstone		232	235	

Date started 7-16, 1988
Date completed 7-22, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	[illegible]	[illegible]	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 27 inches Total depth 235 feet
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
16 inches	0 feet	235 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50'
Gravel packed: Yes ☑ No ☐
Gravel packed from 0 feet to 235 feet
Bottom 2 ft cemented

Perforations:
Type perforation Pacific Mass Louvers
Size perforation 1/8" + 3/32
From 125 feet to 210 Full Flow feet
From 210 feet to 235 Std Flow feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 90' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pliskett Irrigation Co. (Contractor)
Address PO Box 10 Eureka NV 89316 (Contractor)
Nevada contractor's license number 11882
Nevada contractor's drillers number 706
Nevada driller's license number 635 - E. Groth (Actual Driller)
Signed Walter Pliskett (Contractor)
Date 8-12-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434