

OFFICE USE ONLY
 Log No. 30257
 Permit No. _____
 Basin 6-87

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 10024

PRINT OR TYPE ONLY

1. OWNER ROBERT & LINDA FOREMAN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2117 Blossom View 1255 Monte Vista
Sparks, NV 89431 Reno, NV 89511
 2. LOCATION SW 1/4 SE 1/4 Sec 7 T. 20N R. 18E Washoe County
 PERMIT NO. _____ Parcel No. 18N Subdivision Name 20 SW Reno
 Issued by Water Resources _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Cable <input type="checkbox"/>
Recondition <input type="checkbox"/>	Irrigation <input type="checkbox"/>	Rojary <input checked="" type="checkbox"/>
Deepen <input checked="" type="checkbox"/>	Industrial <input type="checkbox"/>	Other <input type="checkbox"/>
Other <input type="checkbox"/>	Test <input type="checkbox"/>	air
	Stock <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL DEEPENING:</u>				
<u>Rylite, purple, sandy</u>		<u>98</u>	<u>125</u>	<u>27</u>
<u>Rylite, purrple, soft</u>		<u>125</u>	<u>134</u>	<u>9</u>
<u>" " med. hard</u>		<u>134</u>	<u>145</u>	<u>11</u>
<u>" " soft</u>	<u>X</u>	<u>145</u>	<u>148</u>	<u>3</u>
<u>" " Med hard</u>		<u>148</u>	<u>151</u>	<u>3</u>
<u>" " soft</u>	<u>X</u>	<u>151</u>	<u>155</u>	<u>4</u>
<u>" " med hard</u>		<u>155</u>	<u>160</u>	<u>5</u>
<u>" " soft</u>	<u>X</u>	<u>160</u>	<u>166</u>	<u>6</u>
<u>" " hard</u>		<u>166</u>	<u>172</u>	<u>6</u>
<u>" " med hard</u>		<u>172</u>	<u>177 1/2</u>	<u>5 1/2</u>
<u>" " hard</u>		<u>177 1/2</u>	<u>178</u>	<u>1 1/2</u>

8. WELL CONSTRUCTION

Diameter 5" inches Total depth 178 feet

_____ inches

_____ inches

Casing record 178' steel liner installed.

Weight per foot _____ Thickness .132

Diameter	From	To
<u>5" liner</u>	<u>0</u> feet	<u>178</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type N/A

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from 135 feet to 178 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3 x 5 around

From 138 feet to 178 feet

From _____ feet to _____ feet

Date started 8-4-88, 19____
 Date completed 8-8-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 12 ft. feet below land surface

Flow 50+ G.P.M. _____ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.

Address P.O. Box 12370, Reno, NV 89510

Contractor _____

Nevada contractor's license number 22549 issued by the State Contractor's Board.

Nevada contractor's driller's number 908 issued by the Division of Water Resources.

Nevada driller's license number 1535 issued by the Division of Water Resources, the on-site driller.

Signed [Signature] By driller performing actual drilling on site or contractor

Date August 15, 1988