

OFFICE USE ONLY
 Log No. 30259
 Permit No. _____
 Basin 99-Red Rock V.

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10237

1. OWNER John Taylor ADDRESS AT WELL LOCATION 670 Appaloosa Cir
 MAILING ADDRESS 670 Appaloosa Cir Rancho Haven
Reno, Nv 89506

2. LOCATION E 1/4 NE 1/4 Sec. 5 T. 23 N/S R. 18 E Washoe County
 PERMIT NO. 078-291-24 - Lot 96 -1
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan yellow white D.G. with traces of brown clay		100	280	180
Sticky clay		280	300	20
Firm D. G.		300	338	38
T.D. 338'				
There is a 20 ft blank on the bottom of the perforation for development work				

8. WELL CONSTRUCTION

Diameter 9 7/8 inches Total depth 338 feet

Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>338</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 338 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3 .188
 From 298 feet to 318 feet
 From _____ feet to _____ feet

Date started 7/26/88, 19____
 Date completed 7/29/88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level _____ feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Contractor
 Address 625 Spice Islands Dr. Suite L Sparks, Nv
 Contractor 89431

Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132

Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 8/1/88