

Date Rec'd 9-28-88  
 OFFICE USE ONLY  
 Log No. 30260  
 Permit No. \_\_\_\_\_  
 Basin 6-84  
 NOTICE OF INTENT NO. 9147

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Henry Walker ADDRESS AT WELL LOCATION Palomino Valley  
 MAILING ADDRESS 2400 Right Hand Canyon Rd.  
Sparks, Nevada 89431

2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 18 T. 22 NSR 22 E Washoe County  
 PERMIT NO. 003315 18-2-2-2 Unit 13 Palomino Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	30	30
Broken rock, sand large boulders		30	70	40
Large to medium gravel, broken rock's, sand, white clay	X	70	160	90
Sandstone w/ small gravel	X	160	170	10
Black, gold, red lava small fractures	X	170	290	120
Sand, rock chips, small gravel	X	290	325	35
Sand, small gravel, clay, broken rock chips	X	325	370	45
Green, Black, Red, Brown lava rock, sandstone	X	370	390	20
Fine sands & gravels	X	390	427	37
Fine sands & small gravel w/ clay	X	427	430	3
Green limestone w/ clay & small gravels	X	430	450	20

8. WELL CONSTRUCTION  
 Diameter 12 1/2 inches Total depth 450 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 8 - 5/8 inch O.D. X 3/16 inch wall  
 Weight per foot \_\_\_\_\_ Thickness \_\_\_\_\_  
 Diameter From To  
8 inches + 1 - 1/2 feet 450 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement grout  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to 450 feet  
3/8 inch minus wadsworth well rock  
 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From shutter 70 feet to 110 feet  
 From slot 110 feet to 230 feet  
 From shutter 250 feet to 270 feet  
 From shutter 290 feet to 450 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started August 11, 19 88  
 Date completed August 29, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Airlft</u>	<u>100</u>		<u>1 1/2</u>

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CHARLES SARGENT IRRIGATION INC.  
Contractor  
 Address 9955 No. Virginia St.  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540  
 Signed [Signature]  
By driller performing actual drilling on site or contractor  
 Date August 31, 1988

BAILER TEST

G.P.M.	Draw down	feet	hours