Date Rec'd 9-1-88

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30265
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10856

1. OWNER ERIC McCLARY
MAILING ADDRESS 6205 FRANKTOWN RD CARSON CITY, NV
ADDRESS AT WELL LOCATION Washoe Pines Ranch 6205 FRANKTOWN RD CARSON CITY, NV

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 16 N/S R. 19 E. WASHOE County
PERMIT NO. ~~W04003317~~ Issued by Water Resources | Parcel No. | NONE Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Sand & boulders to 10"		4	15	11
Granodiorite, hard, fractured		15	87	72
Clay, tight, very hard, yellow		87	193	106
Clay with gravel seams carrying water in small amounts	✓	193	237	40
Fine to course sand		237	240	
T.D. 240FT				

Date started Aug 22, 1988
Date completed Aug 24, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with air to gravel pack			
Blew 20GPM from 240'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 1/4 to 60 inches Total depth 240 feet
Casing record 6 5/8" steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 2 feet

Perforations:
Type perforation Factory Mill
Size perforation 3/32 x 3"
From 215 feet to 235 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level Flowing feet below land surface
Flow 2 G.P.M. 2 P.S.I.
Water temperature Cold °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor
Address 5551 Hiway 50E #3 CARSON CITY, NV 89701 Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number 1472
Nevada driller's license number ..... Actual Driller
Signed Quinton Butts Contractor
Date Aug 26, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434