

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Briley Construction Co ADDRESS AT WELL LOCATION 2090 Palate
Blairton City, NV
WPA Washoe City
 2. LOCATION 1/4 Sec 31 T. 17 N. R. 20 E. Washoe County
 PERMIT NO. WBY 003869 Parcel No. 50-386-12 Subdivision Name

NOTICE OF INTENT NO. 10399

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden, blow sand</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>Sand, fine to coarse</u>		<u>7</u>	<u>40</u>	<u>33</u>
<u>Sand with clay stringers</u>		<u>40</u>	<u>78</u>	<u>38</u>
<u>Clay seams, gray-brown</u>		<u>78</u>	<u>96</u>	<u>18</u>
<u>D.G. lenses</u>	<input checked="" type="checkbox"/>	<u>96</u>	<u>105</u>	<u>9</u>
<u>Granodiorite, semi-hard to hard w/ fractures carrying water</u>	<input checked="" type="checkbox"/>	<u>105</u>	<u>140</u>	<u>35</u>

Note: 5FT blank at bottom filled with pea gravel to inhibit sand

8. WELL CONSTRUCTION
 Diameter 12" to 60 inches Total depth 140 feet
10 3/4" inches
 Casing record 6 5/8" steel
 Weight per foot 11.7 Thickness 1.126

Diameter	From	To
<u>6</u> inches	<u>72</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 95 feet
 Gravel packed: Yes No
 Gravel packed from 95 feet to 140 feet

Perforations:
 Type perforation Factory Mill Slot
 Size perforation 3/32 x 3
 From 115 feet to 135 feet
 From _____ feet to _____ feet

Date started 6/1/88 1988
 Date completed 6/11/88 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
		<u>5</u>	

9. WATER LEVEL
 Static water level 42 feet below land surface
 Flow 14 Gal G.P.M. _____ P.S.I.
 Water temperature 61 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Art H. Jones Co
 Address 5331 New York Ave. Reno NV 89701
 Nevada contractor's license number issued by the State Contractor's Board 73295
 Nevada contractor's driller's number issued by the Division of Water Resources _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
 Signed Art H. Jones
 By driller performing actual drilling on site or contractor
 Date 6/11/88

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours