WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38288
Permit No.
Basin

NOTICE OF INTENT NO. 20594

1. OWNER Pacific West Financial Corp.
MAILING ADDRESS P.O. Box 20519
Reno Nevada 89515

ADDRESS AT WELL LOCATION
1265 Orange Lane
Silver Springs Nevada 89429

2. LOCATION s/w ¼ n/w ¼ Sec. 17 T 18 N/S R 25 E Lyon County

PERMIT NO. xxxxxxxxxx (Issued by Water Resources) | 15-261-15 (Parcel No.) | Pacific West Financial (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 2 | 2 |
| D. Granite | | 2 | 59 | 57 |
| Brown Shale | | 59 | 63 | 4 |
| Sand | | 63 | 72 | 9 |
| Brown Shale | | 72 | 84 | 12 |
| Rock | | 84 | 96 | 12 |
| Brown Shale | | 96 | 110 | 14 |
| White Shale | xxxxx | 110 | 127 | 17 |
| Rock | | 117 | 138 | 11 |
| Brown ~~Shale~~ Clay | | 138 | 170 | 32 |

'92 AUG -6 A11:08
STATE ENGINEER'S OFFICE

Date started July 22, 1992
Date completed July 24, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8-7/8 Inches | Feet | 0 | 170 Feet |
| Inches | Feet | | Feet |
| Inches | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 170 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 110 feet to 130 feet
From 160 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50ft.
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 70 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Warm °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEVADA 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 31, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627