WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30293
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4460

1. OWNER JOHN SMITH
MAILING ADDRESS 825 N. LAMB #250
LAS VEGAS, NEV. 89110

ADDRESS AT WELL LOCATION BRUCE ST.
BETWEEN MOBILE & PAHRUMP
VALLEY BLVD. - PAHRUMP, NEV.

2. LOCATION S.E. ¼ N.W. ¼ Sec. 2 T. 21 N/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) | LOT 29 BLK C (Parcel No.) | GAMEBIRD (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
HARD BROWN CLAY		1	14	13
BROWN CALICHE		14	18	4
WHITE CALICHE		18	29	11
HARD BROWN CLAY		29	36	7
HARD BROWN CALICHE		36	51	15
BROWN CALICHE		51	74	23
HARD BROWN CALICHE		74	76	2
BROWN BENTONITE CLAY		76	81	5
HARD BROWN CALICHE		81	86	5
BROWN CLAY		86	89	3
HARD BROWN CALICHE		89	103	14
BENTONITE CLAY		103	116	13
HARD BROWN CALICHE		116	120	4
BROWN CLAY		120	140	20

RECEIVED JUN 10 1988 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 5-11, 1988
Date completed 5-18, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 140 feet
Casing record 140 FT. 8 5/8" O.D. STEEL
Weight per foot 17.4 Thickness .188

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH CUT
Size perforation 3/8" X 8"
From 70 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 37 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP + DRILLING (Contractor)
Address BOX 157 PAHRUMP, NEV. 89041 (Contractor)
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDIN (Actual Driller)
Signed Ron Floyd (Contractor)
Date 5-20-88

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434