



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 555

PRINT OR TYPE ONLY

1. OWNER RON NAILLON ADDRESS AT WELL LOCATION ISSAC ST. EAST  
OF LESLIE  
 MAILING ADDRESS BOX 265  
PAHRUMP, NEV. 89041  
 2. LOCATION N1/4 N1/4 Sec 8 T. 20 N/S R. 53 E NVE County  
 PERMIT NO. \_\_\_\_\_ Parcel No. LOT 6 BLK A Subdivision Name CHAPPARAL RANCHOS UNIT 2  
 Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material           | Water Strata | From | To  | Thick-ness |
|--------------------|--------------|------|-----|------------|
| TOP SOIL           |              | 0    | 1   | 1          |
| BROWN CLAY         |              | 1    | 7   | 6          |
| BROWN CALICHE      |              | 7    | 33  | 26         |
| HARD BROWN CALICHE |              | 33   | 37  | 4          |
| BROWN CALICHE      |              | 37   | 52  | 5          |
| BROWN CLAY         |              | 52   | 69  | 17         |
| BENTONITE CLAY     |              | 69   | 78  | 9          |
| BROWN CALICHE      |              | 78   | 91  | 13         |
| BENTONITE CLAY     |              | 91   | 98  | 7          |
| BROWN CLAY         |              | 98   | 140 | 42         |

8. WELL CONSTRUCTION  
 Diameter 12 inches Total depth 140 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 14.11 Thickness 156  
 Diameter 8 5/8 inches From 0 feet To 140 feet  
 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Perforations:  
 Type perforation TORCH CUT  
 Size perforation 1/2" X 6"  
 From 80 feet to 140 feet

RECEIVED  
 JUL 19 1988

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 7-12 1988  
 Date completed 7-15 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |

9. WATER LEVEL  
 Static water level 38 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name RON FLOYD PUMP & DRILLING  
 Address BOX 157 PAHRUMP, NEV.  
 Nevada contractor's license number 7479-A  
 Nevada contractor's driller's number 1424  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1427 STAN HARDIN  
 Signed [Signature]  
 Date 7-15-88

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours