WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30322
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER US Ecology Inc.
MAILING ADDRESS PO#578
Beatty Nev. 89003

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 13S N/S R. 47 E. Nye County
PERMIT NO. Under Waiver 401 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand + Gravel		0	15	15
Fine Sand + Gravel		15	278	263
Silty Sand + Gravel		278	288	10
Fine Sand	288		289	1
Silty Sand Gravel				
With Clay		289	321	32
Loose Sand + Gravel	321		420	99

RECEIVED
AUG 9 1988
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started May 3, 19 88
Date completed June 20, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8" inches Total depth 420 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness
Diameter ..... inches From ..... feet To ..... feet
..... inches ..... feet ..... feet
..... inches ..... feet ..... feet
..... inches ..... feet ..... feet
..... inches ..... feet ..... feet
..... inches ..... feet ..... feet
Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 420' feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 287 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address RT 15 Box 543 Amargosa Valley Nev. 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada contractor's driller's number issued by the Division of Water Resources C 23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 14 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627