WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30351
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5068

1. OWNER CLARENCE ROSE
MAILING ADDRESS P.O. BOX 10 BLUE DIAMOND NEV. 89004
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NW ¼ Sec. 36 T. 22 N/S R. 56 E. CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-290-044-88 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY LOAM		0	2	2
CALICHE		2	24	22
WHITE CLAY		24	49	25
CALICHE	WTR	49	50	1
BRN CLAY		50	60	10
CALICHE	WTR	60	62	2
CONS BRN CLAY		62	73	11
BRN CLAY		73	79	6
CORAL		79	87	8
LT BRN CLAY		87	93	6
WHT CLAY		93	103	10
LT BRN CONS CLAY		103	112	9
WHT CLAY		112	123	11
LT BRN CLAY		123	128	5
PALE GREEN CLAY		128	134	6
WHT CLAY		134	138	4
CALICHE		138	142	4
BRN CLAY		142	145	3

RECEIVED MAY 25 1988 Div. of Water Resources Branch Office - Las Vegas, NV

Date started MAY 17, 1988
Date completed MAY 21, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 3 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 145 feet
inches
inches
Casing record STEEL
Weight per foot 12.5 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 145 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4" 4 Rows @ 16" CTRS
From 105 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 64 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC (Contractor)
Address 1701 W CHSTN LAS VEGAS NV 89102 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spurlock (By driller performing actual drilling on site or contractor)
Date MAY 23-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627