WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

ABDD

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30374
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10370

1. OWNER Greg Davies Const
MAILING ADDRESS Box 22
Gardnerville, Nevada

ADDRESS AT WELL LOCATION Parcel 4D
1741 Reed Circle
Minden, Nevada

2. LOCATION NW ¼ NE ¼ Sec. 11 T. 13 N S R. 20 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 23-100-26 Parcel No. | Cecil + Arlene Map Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Cemented gravels, small to 1/2" in clay medium		4	83	79
Gravel with fine sand, small amount of water, 2 gpm	✓	83	86	3
Gravel with clay seams, very tight		86	127	41
Sand, gravels with water	✓	127	158	31
Gravel w/clay		158	160	2
TD 160'				

Date started Sept 23, 1988
Date completed Sept 24, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with 250 psi air & to gravel pack. Blew 15 GPM from 155' for 2 hours to clean & develop			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 60 inches Total depth 160 feet
8 1/2 inches
____ inches
Casing record 6 5/8 Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 160 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 56 feet below land surface
Flow 15 G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co
Contractor
Address 5551 Hwy 50 E Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton Bath
By driller performing actual drilling on site or contractor
Date Sept 27, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627