WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30382
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10373

1. OWNER Don Crisper (Robertson)
MAILING ADDRESS Carson City, Nevada
ADDRESS AT WELL LOCATION 810 Mark Way Carson City, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 5 T. 15 N/S R. 20 E Carson City County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name None

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, Silt & Clay		0	4	4
		4	17	13
D. G. Broken, Gravel size		17	67	40
Granite with fractures @ 57, 67, 85 and 100 feet	✓	57	103	46
T.D. 103 Ft				

Date started Sept 13, 1988
Date completed Sept 13, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed w/ clear water to remove drill mud & to gravel pack. Developed with low volume air for 6 hrs to remove fine sand			

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 12½" to 60' inches Total depth 103 feet
10¾ inches
..... inches
Casing record 8 5/8" Steel
Weight per foot ..... Thickness .188

Diameter	From	To
8 5/8 inches	+ 2 feet	103 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3
From 78 feet to 98 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 15 feet below land surface
Flow 15-20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H Pump Co
Contractor
Address 5551 Hiway 50 E #3 Carson City, NV 89701
Contractor

Nevada contractor's license number issued by the State Contractor's Board 23295

Nevada contractor's driller's number issued by the Division of Water Resources .....

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472

Signed .....
By driller performing actual drilling on site or contractor

Date .....

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627