WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30386
Permit No. —
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10965

1. OWNER BEN BRIXEN
MAILING ADDRESS Box 1149 Carson City, Nevada 89702
ADDRESS AT WELL LOCATION 4460 Voltaire St Carson City Nevada

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 15 N/S R. 20 E Carson City County
PERMIT NO. 85 Co-4 (Issued by Water Resources) | Parcel No. | None (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other Replacement ☑

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	5	5
Brown sand stone		5	137	132
D.G. Hard, with fractures	—	137	260	73
H2O at 137, 243				
T.D. 260 Ft				

Date started Sept. 5, 1988
Date completed Sept 9, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Gravel packed well			reset
250 psi air to develop well			
Blew 12 GPM from 240 Ft			
for 2 hours. Grout sealing			
annular space with bentonite			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth ..... feet
Casing record 6 5/8" Steel
Weight per foot 17 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 260 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 220 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 137 feet below land surface
Flow 12 G.P.M. ..... P.S.I.
Water temperature Cold° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor) 52 & 43
Address 5357 Hilaria Carson City, NV 89701 (Contractor)
Nevada contractor's license number 25795
Nevada contractor's drillers number .....
Nevada driller's license number 1472 (Actual Driller)
Signed Clinton Pritts (Contractor)
Date Sept 9, 1988

(Rev. 6-81)
USE ADDITIONAL SHEETS IF NECESSARY
O-627 CR434