WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30391
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10857

1. OWNER Robert Parise
MAILING ADDRESS 1460 Eunice Way
Carson City, NV

ADDRESS AT WELL LOCATION Lot 1 Blk K
1460 Eunice Way
New Washoe City #2

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 17 N/S R. 20 E Washoe County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources | 50-276-07 Parcel No. | New Washoe City #2 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand & DG		0	4	4
D.G. Med-soft to firm to very hard	✓	4	180	176
First fracture & first water @ 147 about 4 GPM. Next fractures @ 162 and 176 ft				
T.D. 180 ft				

Date started Aug 31, 1988
Date completed Sept 3, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well, with air to gravel pack & develop			
Making 25 GPM from 170 ft			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11½ to 60 inches Total depth 180 feet
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 180 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 155 feet to 175 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cool °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor
5337 Hinsey St #3
Address Carson City, NV 89701 Contractor
Nevada contractor's license number 23245
Nevada contractor's drillers number
Nevada driller's license number 1472 Actual Driller
Signed Quinton R Butt Contractor
Date Sept 6, 1988

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434