

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

page 1 of 2 pages
NOTICE OF INTENT NO. 10295

1. OWNER PRO-MAX CORPORATION ADDRESS AT WELL LOCATION
MAILING ADDRESS P.O. Box 0620 Timberline Drive
Reno, NV 89510 Verdi, Nevada 89439

2. LOCATION SE 1/4 SW 1/4 Sec. 17 T. 19.10N R. 12.12E Washoe County
PERMIT NO. 38-030-10 W of Boomtown NV past firestation
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Cable Rotary
Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray Truckee formation		160	187	27
Soft zone	X	187	190	3
Gray Truckee formation		190	207	17
Soft zone (NO WATER)		207	210	3
Gray Truckee formation		210	232	22
Dark brown " " soft		232	236	4
Truckee formation		236	255	19
Chocklate dark br." sft X	X	255	260	5
Truckee formation		260	274	14
Chocklate dark br." sft X	X	274	277	3
Truckee formation		277	279	2
Soft zone (NO WATER)		279	281	2
Truckee formation		281	294	13
Chocklate dark brown " X	X	294	297	3
Truckee formation		297	317	20
Volcanic rock tight, dark gray				
Chockolate br. Truckee form X	X	317	319	2
Truckee formation with rock streaks		319	322	3
Chockolate brown Truckee X	X	322	333	11
Truckee formation		333	336	3
Truckee formation		336	365	29
Soft zone	X	365	366	1
Truckee formation		366	388	22
Soft zone (NO WATER)		388	391	3
Truckee formation		391	394	3
Soft zone	X	394	401	7

8. WELL CONSTRUCTION

Diameter 5" inches Total depth 500 feet
Casing record 500' steel liner installed.
Weight per foot _____ Thickness .134
Diameter From To
5" inches 0 feet 500 feet
_____ inches _____ feet _____ feet

Surface seal: Yes No Type _____ feet
Depth of seal _____ feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3x 5 around
From 200 feet to 300 feet
From 320 feet to 340 feet
From 360 feet to 380 feet
From 400 feet to 420 feet
From 440 feet to 460 feet

Cont. page 2 of 2 pages:
Date started 9-8-88, 19____
Date completed 9-9-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
Static water level 72 feet below land surface
Flow 250+ G.P.M. _____ P.S.I.
Water temperature 60.1 °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370, Reno, NV 89510 Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed _____ By driller performing actual drilling on site or contractor
Date September 12, 1988

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

Page 2 of 2 pages
 NOTICE OF INTENT NO. 10295

1. OWNER PRO-MAX CORPORATION ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 0620 Timberline Drive
Reno, NV 89510 Verdi, NV 89439

2. LOCATION SE 1/4 SW 1/4 Sec. 17 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. 38-030-10 W of Boomtown, NV past firestation
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Continued from page 1 of 2 pages.				
Gray Truckee formation		401	438	37
Soft zone	X	438	443	5
Light brown Truckee formation		443	445	2
Multi-color soft zone	X	445	455	10
Gray Truckee formation		455	461	6
Dark brown " "		461	465	4
Gray Truckee formation		465	470	5
Light gray " "		470	498	28
Dark gray " "		498	500	2

8. WELL CONSTRUCTION

Diameter 5" inches Total depth 500 feet

Casing record 500' steel casing installed

Weight per foot _____ Thickness .134

Diameter	From	To
<u>5</u> inches	<u>0</u> feet	<u>500</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From cont. from page 2 of 2 pages feet
 From _____ feet to _____ feet
 From 480 feet to 500 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-8-88, 19____
 Date completed 9-9-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 72 feet below land surface

Flow 250+ G.P.M. _____ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number 22549
 issued by the State Contractor's Board

Nevada contractor's driller's number 908
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date September 12, 1988

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours