

BBAA

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 9183

PRINT OR TYPE ONLY

1. OWNER Tom and Maxine Bacon ADDRESS AT WELL LOCATION 5036 Pleasant View Dr
 MAILING ADDRESS 5035 Pleasant View Dr
Sparks, Nv 89431

2. LOCATION NW 1/4 Sec 1 T. 19 N/S R. 20 E Washoe County
 PERMIT NO. 030-203-06 - Sunset View Rancho Estates Unit # 2
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Volcanic rock | | 394 | 405 | 11 |
| Volcanic clay & gravels | | 405 | 485 | 80 |
| Volcanic rock | | 485 | 490 | 5 |
| Reddish volcanic clay with rock lenses | | 490 | 570 | 80 |
| Gray clay some rock | | 570 | 583 | 13 |
| Brown clay | | 583 | 624 | 41 |
| Gray green rock with yellow & dark black | | 624 | 685 | 61 |
| Reddish brown rock | | 685 | 690 | 5 |
| Green gray yellow & brown rock fractured | | 690 | 700 | 10 |
| T.D. 700 feet | | | | |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 700 feet

Casing record 6 5/8" and 5"
 Weight per foot 10.78 6.96 Thickness .156 & .134

| Diameter | From | To |
|---------------------|--------------------|-----------------|
| <u>6 5/8</u> inches | <u>+1 1/2</u> feet | <u>290</u> feet |
| <u>5</u> inches | <u>271</u> feet | <u>700</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type _____ feet
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 660 feet to 700 feet
 From _____ feet to _____ feet

Date started 9/6/88, 19____
 Date completed 9/9/88, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------------------------------|--------|-----------|------------------|
| Blew with air to clean and develop. | | | |
| | | | |
| | | | |
| | | | |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 220 feet below land surface
 Flow 20+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
Contractor
 Address 625 Spice Islands Dr. Suite L Sparks, Nv
Contractor 89431
 Nevada contractor's license number 15291
issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
issued by the Division of Water Resources
 Nevada driller's license number issued by the 1132/1511
Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date 9/12/88