

**WELL DRILLER'S REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 10865

1. OWNER CROMWELL CONSTRUCTION ADDRESS AT WELL LOCATION 1303 YUCCA  
 MAILING ADDRESS 1195 CLYDE JR ROAD FALLON, NV 89406  
 FALLON, NV 89406  
 2. LOCATION SE 1/4 NW 1/4 Sec 8 T 19 N/S R 29 E CHURCHILL County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	5	5
SANDY CLAY		5	26	21
SAND	X	26	48	22
CLAY		48	56	8
BLACK SAND	X	56	78	22
BLACK CLAY		78	83	5
GRAY SAND	X	83	124	41
CLAY		124	136	12
GRAY SAND	X	136	169	33
CLAY		169	200	31
SAND & GRAVEL	X	200	212	12

8. WELL CONSTRUCTION  
 Diameter 6 5/8 inches Total depth 212 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8 X 212  
 Weight per foot 12.9 Thickness .188  

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>6</u> inches	<u>50</u> feet	<u>212</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation 3/32 X 3  
 From 202 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started SEPTEMBER 6 1988  
 Date completed SEPTEMBER 8 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR BLOWN @ 15 GPM</u>			

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 65 °F Quality UNKNWN

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WELSCO CORP. Contractor  
 Address P.O. BOX 888 FALLON, NV 89406 Contractor  
 Nevada contractor's license number 11752 issued by the State Contractor's Board  
 Nevada contractor's driller's number 772 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date SEPTEMBER 12