WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30417
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11659

1. OWNER I. V. Meeks
MAILING ADDRESS 2270 Lucas Road Fallon Nevada 89406
ADDRESS AT WELL LOCATION 2270 Lucas Road Fallon, Nev 89406

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 19 N/S R. 29 E. Churchill County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Silt + Sand (Coarse)		5	7	2
Clay		7	8	1
Fine Sand		8	10	2
Clay		10	29	19
Sand (Fine)		29	32	3
Clay		32	42	10
Tule Sand (Stinks)		42	43	1
Tule Clay		43	58	15
Tule Gravel		58	60	2
Clay + Sand (Fine)		60	75	15
Gray Clay		75	80	5
Gray Sand		80	88	8
Brown Clay (No stink)		88	97	9
Sandy Gravel	✓	97	107	10
Tight Sand (Hard)		107		
9-Sack Mix				
Grout 1½ yds				

Date started Sept 10, 1988
Date completed Sept 15, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	35	22 ft	4 hrs.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 107 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
12 inches	0 feet	50 feet
8 inches	0 feet	107 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete Grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Machined
Size perforation 3/32 x 2" double perforated
From 100 feet to 107 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Jr
Contractor
Address 2900 Tarzyn Rd Fallon Nv
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada contractor's driller's number issued by the Division of Water Resources 1455
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr
By driller performing actual drilling on site or contractor
Date Sept 15, 1988

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627