

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10323

1. OWNER BILL RAINS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10350 Trail drive Same
Reno, NV 89506
 2. LOCATION SW 1/4 SW 1/4 Sec 1 T 20N N/S R. 18 E Washoe County
 PERMIT NO. _____ APN: 81-03 1-09 Anderson Acers
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Broken rock w/some clays		0	1 1/2	1 1/2
Brown clays w/brokeen volcanic rock		1 1/2	189	187 1/2
Soft zone (2 GPM)	X	189	195	6
Brown sandy clay		195	210	15
Brown volcanic rock		210	253	42
Gray clay		253	311	58
Soft zone (NO WATER)		311	314	3
Gray clay		314	325	11

NOTE: From 212 to 325 test hole only
 no casing installed.

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 212 feet

Casing record 212' steel casing installed.

Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>212</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement

Depth of seal 51 feet

Gravel packed: Yes No

Gravel packed from 51 feet to 212 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3" XX x 6 around

From 160 feet to 200 feet

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 78 feet below land surface

Flow 2 G.P.M. _____ P.S.I.

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.
Contractor

Address P.O. box 12370, Reno, NV 89510
Contractor

Nevada contractor's license number 22549
 issued by the State Contractor's Board.

Nevada contractor's driller's number 1908
 issued by the Division of Water Resources.

Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.

Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor

Date August 25, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____