WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30422
Permit No.
Basin 5-76

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10859

1. OWNER SCHORSCH
MAILING ADDRESS 2325 FARM DISTRICT RD
FERNLEY NV 89408

ADDRESS AT WELL LOCATION 2325 FARM DISTRICT RD
FERNLEY NV 89408

2. LOCATION NW ¼ SE ¼ Sec. 20 T. 20 N/S R. 25 E. LYON County
PERMIT NO. (Issued by Water Resources) | 21-303-18 (Parcel No.) | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Clay & cobbles		4	16	12
gravel		16	28	12
Clay & cobbles		28	48	20
Rock		48	60	12
Clay & gravel	✓	60	70	10
Clay, Brown		70	81	11
Clay & Gravel	✓	81	121	40
Clay, Gravel Sand	✓	121	135	14

Date started 8-25-88 Aug 22 19 88
Date completed Aug 24 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR Blow @	30 G.P.M.		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 135 feet
..... inches
..... inches
Casing record 6 5/8 X 135
Weight per foot 12.9 Thickness .188

Diameter	From	To
10 inches	0 feet	50 feet
6 inches	50 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Machine slot
Size perforation 1/8 x 3
From 121 feet to 131 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 33 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 62 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welco Corp (Contractor)
Address Box 888 Fallon (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-6-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627