

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10940

1. OWNER CRAIG RODGERS ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1620 1/2 "G" Street 40 Rodgers Ranch Road
Sparrks, NV 89431 Sparks, NV 89431
2. LOCATION SE 1/4 NE 1/4 Sec. 32 T. XX 21N. N/S R. 21E E Washoe County
PERMIT NO. 76-690-04 Spanish Springs
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input checked="" type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy top soil		0	2	2
Tan sandy clay		2	30	28
Brown sandy clay		30	84	54
Gray " "		84	137	53
Brown " "		137	166	29
Gray " "		166	232	66
Gray " " w/				
rock streaks		232	261	29
Tan sandy clay		261	270	9
Orangish brown sandy				
cclay		270	305	35
Brown sandy clay		305	320	15
Gray " "		320	359	39
Gray volcanic rock		359	390	31
Orangish brown clay		390	421	31
Soft zone		421	423	2
Brown volcanic rock		423	432	9
Soft zone (est. 1 GPM)	X?	432	434	2
Gray volcanic rock		434	510	76
Redish gray volcanic rock		510	531	21
Gray & dark brown				
volcanic rock		531	585	54
Pinkish red rock		585	600	15
Brown rock volcanic		600	615	15
Pinkish red volcanic		615	629	14
Black volcanic rock hard		629	650	21

NOTE: TEST HOLE ABANDONE & CEMENTED.

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 650 feet
_____ inches
_____ inches
Casing record. No casing installed.
Weight per foot _____ Thickness _____
Diameter From To
_____ inches _____ feet _____ feet
Surface seal: Yes No Type _____
Depth of seal _____ feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet
Perforations:
Type perforation _____
Size perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 8-24-88, 19____
Date completed 8-26-88, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 375 after 15 hrs _____ feet below land surface
Flow 1 G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc.
Address P.O. Box 12370, Reno, NV 89510
Nevada contractor's license number 22549
Nevada contractor's driller's number 908
Nevada driller's license number issued by the 923
Division of Water Resources, the on site driller _____
Signed [Signature]
By driller performing actual drilling on site or contractor
Date August 31, 1988