WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

CONFIDENTIAL-UNTIL APR. 1993
NRS 534.037.

OFFICE USE ONLY
Log No. 30429
Permit No.
Basin

NOTICE OF INTENT NO.

1. OWNER AMOR II Corporation
MAILING ADDRESS 610 East Glendale Ave.
Sparks, NV 89431

ADDRESS AT WELL LOCATION NA
Well No. 53-21

2. LOCATION SE ¼ NW ¼ Sec. 21 T. 29 N R. 23 E. Washoe County
PERMIT NO. 51816 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Altered Lithic Tuff		0'	30'	30'
Crystal-Lithic Tuff		30'	50'	20'
Lithic Tuff		50'	110'	60'
Tuff		110'	160'	50'
No Sample (air drill)		160'	350'	190'

CONFIDENTIAL-UNTIL APR. 1993
NRS 534.037.

RECEIVED AUG 31 '88 AM 10:01
STATE ENGINEER'S OFFICE

Date started March 3, 19 88
Date completed March 18, 19 88

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flow	1700	0	

BAILER TEST (N/A)
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. (hole) WELL CONSTRUCTION
Diameter 26 inches Total depth 350 feet
17-½ inches
inches
Casing record
Weight per foot 94 & 60#/ft. Thickness k-55

Diameter	From	To
20 inches	0 feet	108 feet
13-3/8 inches	40 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 102 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from N/A feet to feet

Perforations:
Type perforation -Mill Slot-
Size perforation 2.5" X 0.25"-32 per foot
From 80 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 0 feet below land surface
Flow 1700 G.P.M. 38 P.S.I.
Water temperature 278 °F Quality approx TDS - 4200

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Materi Exploration, Inc. (Contractor)
Address P.O. Box 500, Upton, WY 82730 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 18103
Nevada contractor's driller's number issued by the Division of Water Resources C-23
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1549
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-16-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627