WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 30456
Permit No.
Basin 4-4 N. Fork

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Gil States ADDRESS 520 commercial st
Elko NEV

2. LOCATION N/E ¼ N/W ¼ Sec. 1 T. 35 N/S R. 56 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	25	25
clay - sand		25	35	10
gravel - sand		35	60	25
fine sand		60	70	10
Gravel - sand		70	90	20
clay - sand		90	100	10

'88 SEP -9 A9:30
STATE ENGINEER'S OFFICE

Date started 6/18/88, 19
Date completed 6/21/88, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 35 Draw down 5 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 100 feet
Casing record
Weight per foot Thickness 15.6

Diameter	From	To
6 inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 100' feet

Perforations:
Type perforation factory
Size perforation 1/8 x 3"
From 60' feet to 100' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mike Davis
Address P.O. Box 54 Elko Nev 89801
Nevada contractor's license number 20684
Nevada driller's license number 1191
Signed Mike Davis
Date 6/24/88

USE ADDITIONAL SHEETS IF NECESSARY

O-627