WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 30437
Permit No. 52471
Basin 4-4a Elko Segment

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10705

1. OWNER Elko Blacksmith Shop, Inc.
MAILING ADDRESS P.O. Box 510
Elko, NV 89801

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 29 T. 35 N/S R. 56 E. Elko County
PERMIT NO. SE-005 Issued by Water Resources | Parcel No. | Subdivision Name
WAIVER

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☒

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0' | 5' | 5' |
| Sand & Gravel | | 5' | 25' | 20' |
| Gravel w/clay | | 25' | 30' | 5' |
| Clay w/some gravel | | 30' | 35' | 5' |
| Sand & Gravel w/some clay | | 35' | 55' | 20' |
| Coarse sand w/some clay | | 55' | 140' | 85' |
| First water at 35' | | | | |

STATE ENGINEER'S OFFICE
'88 SEP 29 A9:45

Date started 9-6, 1988
Date completed 9-24, 1988

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| BLOW TEST | 10 gpm | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 141 feet
inches
inches
Casing record
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 inches | +1.5 feet | 120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 141 feet

Perforations:
Type perforation Machine slots
Size perforation 1/8"
From 120 feet to 141 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. Contractor
Address P.O. Box 850 Contractor
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada contractor's driller's number issued by the Division of Water Resources 1166
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1166
Signed [signature] By driller performing actual drilling on site or contractor
Date 9-26-88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627