WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 30447
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10874

1. OWNER Mrs Vera Gross
MAILING ADDRESS 209 Autumn Hills Rd
Gardnerville, NV

ADDRESS AT WELL LOCATION 209 Autumn Hills Road
Gardnerville, Nevada

2. LOCATION SW ¼ (SW) ¼ Sec. 3 T. 12 N/S R. 19 E/W Douglas County
PERMIT NO. None (Issued by Water Resources) 19-350-05 (Parcel No.) Autumn Hills (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other Replacement ☑

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Boulders with Sand seams		4	90	86
Hard fractured Granite		90	130	40
Gravels with Water, fairly Clean with Very little sand	✓	130	140	10
Fractured Granite Hard	✓	140	160	40
T.D. 160 feet				

Date started Oct 6, 19
Date completed Oct 10, 1988

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well to develop 4 grand			
Peak for 3 hours			
Blowing 30+ GPM from 150'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60' inches Total depth 160 feet
8 3/4 inches
inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 inches	+2 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 160 feet

Perforations:
Type perforation Factory mill slot
Size perforation 3/32 x 3"
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23795
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Oct 11, 1988

STATE ENGINEER
OCT 14 A9 '88

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627